

## Distribution:

Part 1--(White)--Job File

Part 2--(Yellow)--Inspector

BCA-328 (Rev. 8-78)

## DEPARTMENT OF PUBLIC WORKS

City of Los Angeles


Bureau of Contract Administration

PAGE \_\_\_\_ OF \_\_\_\_

FROM: 03/21/00

TO: 03/21/00

## CONSTRUCTION INSPECTOR'S DAILY JOB REPORT

JOB TITLE: 190TH STREET @ NORMANDIE SW CORNER		JOB NO: BC 600290
DATE	Description of Work done, Contractor, Limits, Quantities, Sampling, Instructions to Contractor (See Bureau Manual, 91-3 Records & Reports.)	
Tue. 03/21/00	<b>SUPERVISION:</b> (P) BAYLEY CONSTRUCTION <b>SURFACE:</b> (S) BALI CONSTRUCTION: Due to a broken 2" domestic water line break on the north side of Francisco Street at approximate STA 28+50, the contractor had to jackhammer through the pavement, made the necessary repair, then backfilled with one-sack slurry. <i>NOTE: This Inspector found Doty Brothers, on contract to Department of Water and Power Re-line Division, had sawcut and removed a width of 8-9" the full width of Harbor Gateway (42 feet), in order to place a temporary water service from the hydrant on the west side of Harbor Gateway to the Boeing Facility on the east side of Harbor Gateway at the location of the new, yet to be constructed Knox Street. They had no permit for this work. This is a new street (less than one year old) and falls under City Ordinance # 171922, which I advised the parties of. This street was recorded on 06/02/99. The responsible parties are:</i> <b>DEPT OF WATER AND POWER--RE-LINE DIVISION</b> <b>SUPERVISOR: MIKE GRAYAC</b> <b>PHONE: (213) 367-1039 or (213) 367-1049</b> <b>PAGER: (213) 209-8500</b> <b>DOTY BROS. PIPELINE CONTRACTORS</b> <b>FOREMAN: RON BRAH</b> <b>PHONE: (310) 613-8822</b>  Charlene L. Metcalf 2.0 Hr. Sr. Construction Inspector	

## Distribution:

Part 1---(White)---Job File  
 Part 2---(Yellow)---Inspector  
 BCA-328 (Rev. 8-78)



DEPARTMENT OF PUBLIC WORKS  
 City of Los Angeles  
 Bureau of Contract Administration

PAGE \_\_\_\_ OF \_\_\_\_

FROM: 03/22/00

TO: 03/23/00

## CONSTRUCTION INSPECTOR'S DAILY JOB REPORT

JOB TITLE: 190TH STREET @ NORMANDIE SW CORNER		JOB NO. BC 600290	
Description of Work done, Contractor, Limits, Quantities, Sampling, Instructions to Contractor (See Bureau Manual, B1-5 Records & Reports.)			
DATE			
Wed. 03/22/00	NOTE: Regarding the incident yesterday where the Dept. of Water and Power had excavated though the new pavement on Harbor Gateway---see yesterday's report---I spoke with Victor Osugi, Principal Civil Engineer, Bureau of Street Services. He advised me to contact Mike Grayac, D.W.P.---Re-line Division to tell him to call Mr. Bill White, Assistant Director of the Bureau of Street Services who would inform him of their responsibility to re-pave the whole street.		
	 Charlene L. Metcalf 0 Hrs. Sr. Construction Inspector		
Thur. 03/23/00	NOTE: Contacted Mike Grayac, D.W.P., Re-line Division and informed him that he was to call Mr. Bill White, Assistant Director of the Bureau of Street Services at Phone: (213) 485-5681.		
	 Charlene L. Metcalf 0 Hrs. Sr. Construction Inspector		